



Account Name:

Asset Location (Service Address):

Asset:

Engine	Generator
cat	

## Load Test Report

Engine Fluids:	Load Test Reports	Test Equipment
Engine Fluids: <input type="text" value="Good"/> Oil Level <input type="text" value="Good"/> Coolant Level <input type="text" value="Full"/> Starting Fuel Level <input type="text"/> Ending Fuel Level	Serviceperson: <input type="text" value="Kish"/> Test Date: <input type="text" value="17-Apr-19"/> Time In: <input type="text" value="1:50 PM"/> Time Out: <input type="text"/> Total Time: <input type="text" value="1 hr"/>	Make: <input type="text"/> Model: <input type="text"/> Serial #: <input type="text"/>

Load Step (kW/min)	Time	Hour Meter	Volt Meter	Frequency (Hz)	Power (kW)	Leg A Amps	Leg B Amps	Leg C Amps	Oil Press (PSI)	Water Temp (F)	Ambient Temp
0/5	11:48 AM	278.00	482	59.1	353.1	422.8	421.7	421.4	55	187	
200/10	11:53 AM	278.00	482	59.1	353.4	422.8	421.7	421.4	54	188	
550/10	11:58 AM	278.00	482	59	358.7	429	427.9	427.9	54	189	
750/10	12:03 PM	278.00	482	59	364	435.3	434.1	433.9	54	190	
980/20	12:08 PM	278.00	482	59	369.1	441.4	440.2	440	53	194	
0/5	12:13 PM	278.00	482	59	369.4	441.8	440.9	440.4	53	196	
	12:18 PM	278.00	482	59	368.5	441.8	440.8	440.3	53	198	
	12:23 PM	278.00	482	59	369.2	441.7	440.8	440.3	53	199	
	12:28 PM	278.00	482	59	366.8	441.8	440.9	440.3	52	199	
	12:30 PM	278.00	482	59	380.1	454.5	453.5	453	52	201+	

Account Name:

5711 brittmoore rd

Work Order:

