



Load Test Report

Account Name:

Asset Location (Service Address):

Asset:

Man.
Model

Engine

Generator

Engine Fluids:

Engine Fluids:

Full	Oil Level
Full	Coolant Level
16%	Starting Fuel Level
13%	Ending Fuel Level

Load Test Reports

Serviceperson:

Test Date

23-Sep-25

Time In

12:30 PM

Time Out

1:30 PM

Total Time:

1.00

Test Equipment

Make

Model

Serial #

Load Step (kW/min)	Time	Hour Meter	Volt Meter	Frequency (Hz)	Power (kW)	Leg A Amps	Leg B Amps	Leg C Amps	Oil Press (PSI)	Water Temp (F)	Ambient Temp
31%	12:30 PM	16,569.00	480	60	75	92	92	92	45	150	87
65%	12:45 PM	16,569.00	480	60	158	190	190	190	40	190	87
86%	1:00 PM	16,569.00	480	60	208	252	252	252	39	197	87
100%	1:15 PM	16,570.00	480	60	240	288	288	288	37	208	87
0%	1:30 PM	16,570.00	480	60	0	0	0	0	35	176	87

Account Name:

5931 Brittmoore Rd.

Work Order:

101184