



Load Test Report

Account Name:

Asset Location (Service Address):

Asset:

Man.
Model

Engine

Generator

Engine Fluids:

Engine Fluids:

Full	Oil Level
Full	Coolant Level
75%	Starting Fuel Level
70%	Ending Fuel Level

Load Test Reports

Serviceperson:

Test Date

25-Sep-25

Time In

1:00 PM

Time Out

2:00 PM

Total Time:

1.00

Test Equipment

Make

Model

Serial #

Load Step (kW/min)	Time	Hour Meter	Volt Meter	Frequency (Hz)	Power (kW)	Leg A Amps	Leg B Amps	Leg C Amps	Oil Press (PSI)	Water Temp (F)	Ambient Temp
31%	1:00 PM	346.90	208	60	45	125	125	125	78	180	86
65%	1:15 PM	346.30	208	60	90	250	250	250	67	185	86
86%	1:30 PM	346.50	208	60	135	373	373	373	64	187	86
100%	1:45 PM	346.80	208	60	170	469	469	469	62	189	86
0%	2:00 PM	347.00	208	60	170	469	469	469	61	189	86

Account Name:

5931 Brittmoore Rd.

Work Order:

101275